



ADDENDUM NO. 2

April 15, 2021

**STATE OF MARYLAND
DEPARTMENT OF GENERAL SERVICES**

Ellington E. Churchill, Jr, Secretary

**PROJECT NO. ND-150-172-003
Department of Juvenile Services
Resurface Asphalt Campus Wide at Garrett Children's Center and
Backbone Mountain Boys Camp**

This Addendum will clarify, add to, delete from, correct and/or change the bid documents for the project referenced above to the extent indicated. This Addendum is hereby made a part of the bid documents on which the contract will be based. By submitting a bid for this solicitation, you acknowledge receipt of this addendum. All questions must be in writing and addressed to the Procurement Officer, Kim Langkam and emailed to Kimberly.langkam@maryland.gov.

This Addendum includes questions and answers, and an attached sketch.

Question: Can there be an inlet or junction box added where the New 6' perf PVC, existing 12" storm and the NEW 15" Elliptical Steel pipe come together. There is NO WAY to connect all three (different) pipes without an inlet or junction box.

Answer: Yes - Add a junction box as required to connect the pipes as identified above. See attached sketch.

Question: 2. Where the new 15" elliptical pipe is connect to the existing 15" pipe, can there be an inlet or junction box added there as well?

Answer: Yes - Add a junction box as required to connect the elliptical pipe to the existing pipe. See attached sketch.

Question: The plans indicate that the parking lot beside the two storm ponds is to receive a mill and overlay. However, it is also showing a grade change (per the contours). We cannot create a grade change by simply doing a mill and overlay. If this area is to require a grade change then it would be better to do full depth repair. If full-depth is not done, then there will be no change to the runoff flow pattern.

Answer: The area adjacent to the storm ponds requires varied milling to achieve the grades indicated.

ATTACHMENT: Sketch

Issued by:

State of Maryland
Department of General Services
Office of State Procurement
301 West Preston Street
Room M-7
Baltimore, Maryland 21201

Kim Langkam

Kim Langkam
Procurement Officer